


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1501-002 M94345	FAN, NO.2 DISC THICKENER HOOD EXHAUST (B-LINE)	BYRD HARTZELL 46C-24-CSL3 3500 CFM 2.5" SP		CR-94-L-0096-D   2001-21-19	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1501-002M E94345 U62-11-9FB NEW	MOTOR, DISC THICKENER HOOD EXHAUST FAN (B-LINE)	BYRD	5866 5 HP 1800 184T	CR-94-L-0096-D   	SP-1501-1  445022	04 INSTALLED BY BYRD
310-1501-015 M94650	FAN, WELDING EXHAUST	BYRD CAR-MON #CMB SPARK PROOF 10F ARR 10 1000 CFM 3" SP		CR-94-L-0096-D CR-94-M-0037-D  2001-21-18	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1501-015M E94650	MOTOR, WELDING EXHAUST FAN	BYRD	0.5 HP (est) 1800	CR-94-L-0096-D CR-94-M-0037-D	SP-1501-1  445022	06 SUPPLIED WITH EQUIP.
310-1502-001 M94665	A/C UNIT, NO.1 RACK ROOM	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0036-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-001M E94665 U62-11-4FCR NEW	MOTOR, NO.1 RACK ROOM A/C UNIT	BYRD	5878 1 HP 1800 14 AMPS H143T	CR-94-L-0095-D   	SP-1501-1  445022	06 SUPPLIED WITH EQUIP.
310-1502-002 M94666	A/C UNIT, NO.2 RACK ROOM	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0036-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-002M E94666 U62-11-6RDL NEW	MOTOR, NO.2 RACK ROOM A/C UNIT	BYRD	5879 1 HP 1800 14 AMPS H143T	CR-94-L-0095-D CR-94-M-0036-D	SP-1501-1  445022	06 SUPPLIED WITH EQUIP.

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Project no: AFCP-001	Page: 102 of 152
			Document no: 990-01-0901	Revision: 08  Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-1502-003 M94675  NEW	A/C UNIT, NO.1 MCC ROOM	BYRD TRANE CO. SIWFN 7244 72 TONS		CR-94-L-0094-D CR-94-M-0015-D  2001-21-11	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-003M E94675 U62-11-4FE NEW	MOTOR, NO.1 MCC ROOM A/C UNIT	BYRD  110 AMPS	5891 25 HP 1800 284T	CR-94-L-0094-D CR-94-M-0015-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.
310-1502-004 M94676  NEW	A/C UNIT, NO.2 MCC ROOM	BYRD TRANE CO. SIWFN 7244 72 TONS		CR-94-L-0094-D CR-94-M-0017-D  2001-21-11	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-004M E94676 U62-11-4FF NEW	MOTOR, NO.2 MCC ROOM A/C UNIT	BYRD  110 AMPS	5892 25 HP 1800 284T	CR-94-L-0094-D CR-94-M-0017-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.
310-1502-005 M94677  NEW	A/C UNIT, NO.1 LOCKERS / CONTROL ROOM / LAB	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0035-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-005M E94677 U62-11-4FCL NEW	MOTOR, NO.1 LOCKERS / CONTROL ROOM / LAB A/C UNIT	BYRD  14 AMPS	5880 1 HP 1800 H143T	CR-94-L-0095-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.
310-1502-006 M94678  NEW	A/C UNIT, NO.2 LOCKERS / CONTROL ROOM / LAB	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0035-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-006M E94678 U62-11-3FFR NEW	MOTOR, NO.2 LOCKERS / CONTROL ROOM / LAB A/C UNIT	BYRD  14 AMPS	5881 1 HP 1800 H143T	CR-94-L-0095-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 103 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1502-007 M94679  NEW	A/C UNIT, NO.3 LOCKERS / CONTROL ROOM / LAB	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0035-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-007M E94679 U62-11-3FFL NEW	MOTOR, NO.3 LOCKERS / CONTROL ROOM / LAB A/C UNIT	BYRD	5882 1 HP 1800 H143T	CR-94-L-0095-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.
310-1502-008 M94700  NEW	A/C UNIT, NO.4 CONFERENCE ROOM/OFFICES	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0036-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-008M E94700 U62-11-4FDL NEW	MOTOR, NO.4 CONFERENCE ROOM/OFFICES A/C UNIT	BYRD	5883 1 HP 1800 H143T	CR-94-L-0095-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.
310-1502-009 M94701  NEW	A/C UNIT, NO.5 CONFERENCE ROOM/OFFICES	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0036-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-009M E94701 U62-11-4FDR NEW	MOTOR, NO.5 CONFERENCE ROOM/OFFICES A/C UNIT	BYRD	5884 1 HP 1800 H143T	CR-94-L-0095-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.
310-1502-010 M94702  NEW	A/C UNIT, NO.6 CONFERENCE ROOM/OFFICES	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0037-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-010M E94702 U62-11-6RDR NEW	MOTOR, NO.6 CONFERENCE ROOM/OFFICES A/C UNIT	BYRD	5885 1 HP 1800 H143T	CR-94-L-0095-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.


 <b>AJAMI, BEDARD, GAGNON, SEXTON INC.</b> PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 104 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1502-011 M94703  NEW	A/C UNIT, NO.7 CONFERENCE ROOM/OFFICES	BYRD CLIMATE MASTER GENESIS GRV 060 5 TONS		CR-94-L-0095-D CR-94-M-0037-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-011M E94703 U62-11-3RFL NEW	MOTOR, NO.7 CONFERENCE ROOM/OFFICES A/C UNIT	BYRD	5886 1 HP 1800 H143T	CR-94-L-0095-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP.
310-1502-012 M94695  NEW	FAN, LABORATORY FUME HOOD EXHAUST	BYRD TWIN CITY RBO/R CL22 907 ARR.10 316SS 450 CFM 1"SP		CR-94-L-0096-D CR-94-M-0035-D  2001-21-17	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-012M E94695  NEW	MOTOR, LABORATORY FUME HOOD EXHAUST FAN	BYRD	0.25 HP (est) 1800	CR-94-L-0096-D	SP-1501-1  445022	06 115V/1/60 SUPPLIED WITH EQUIP.
310-1502-013 M94696  NEW	FAN, LADIES/WASH ROOM EXHAUST			CR-94-L-0096-D	445022	06 INSTALLED BY BYRD
310-1502-013M E94696  NEW	MOTOR, LADIES/WASHROOM EXHAUST FAN		0.25 HP (est) 1800	CR-94-L-0096-D	445022	06 115V/1/60 SUPPLIED WITH EQUIP.
310-1502-014 M94697  NEW	FAN, LOCKERS EXHAUST	BYRD TWIN CITY RBO/R CL22 909 ARR.10 ALUM 800 CFM @ 1/4" SP		CR-94-L-0096-D CR-94-M-0035-D  2001-21-16	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1502-014M E94697  NEW	MOTOR, LOCKERS EXHAUST FAN	BYRD	0.5 HP (est) 1800	CR-94-L-0096-D	SP-1501-1  445022	06 115V/1/60 SUPPLIED WITH EQUIP.

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 105 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02



EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1502-015 M94698  NEW	FAN, MENS WASHROOM EXHAUST	100 CFM			CR-94-L-0096-D  445022	06 INSTALLED BY BYRD
310-1502-015M E94698  NEW	MOTOR, MENS WASHROOM EXHAUST FAN		0.25 HP (est) 1800		CR-94-L-0096-D  445022	06 115V/1/60 SUPPLIED WITH EQUIP.
310-1502-016 M94699  NEW	FAN, MENS WASHROOM EXHAUST	100 CFM			CR-94-L-0096-D  445022	06 INSTALLED BY BYRD
310-1502-016M E94699  NEW	MOTOR, MENS WASHROOM EXHAUST FAN		0.25 HP (est) 1800		CR-94-L-0096-D  445022	06 115V/1/60 SUPPLIED WITH EQUIP.
310-1503-005 M94610  NEW	FAN, NO.1 ROOF EXHAUST	BYRD HARTZELL 70-60-AWN3 50000 CFM 1/4" SP			CR-94-L-0096-D CR-94-M-0031-D  2001-21-1 445022	06 INSTALLED BY BYRD
310-1503-005M E94610 U62-11-2RC NEW	MOTOR, NO.1 ROOF EXHAUST FAN	TOSHIBA TEFC	5075 10 HP 1800 215T		CR-94-L-0096-D CR-94-M-0031-D  445013	04 INSTALLED BY BYRD
310-1503-006 M94611  NEW	FAN, NO.2 ROOF EXHAUST	BYRD HARTZELL 70-60-AWN3 50000 CFM 1/4" SP			CR-94-L-0096-D CR-94-M-0027-D  2001-21-1 445022	06 INSTALLED BY BYRD
310-1503-006M E94611 U62-11-2RD NEW	MOTOR, NO.2 ROOF EXHAUST FAN	TOSHIBA TEFC	5076 10 HP 1800 215T		CR-94-L-0096-D CR-94-M-0027-D  445013	04 INSTALLED BY BYRD

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 106 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1503-007 M94612  NEW	FAN, NO.3 ROOF EXHAUST	BYRD HARTZELL 70-60-AWN3 50000 CFM 1/4" SP		CR-94-L-0096-D CR-94-M-0032-D  2001-21-1	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-007M E94612 U62-11-2RE NEW	MOTOR, NO.3 ROOF EXHAUST FAN	TOSHIBA TEFC	5077 10 HP 1800 215T	CR-94-L-0096-D CR-94-M-0032-D	SP-4200-2  445013	04 INSTALLED BY BYRD
310-1503-008 M94613  NEW	FAN, NO.4 ROOF EXHAUST	BYRD HARTZELL 70-60-AWN3 5000 CFM 1/4" SP		CR-94-L-0096-D CR-94-M-0028-D  2001-21-1	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-008M E94613 U62-11-2RF NEW	MOTOR, NO.4 ROOF EXHAUST FAN	TOSHIBA TEFC	5078 10 HP 1800 215T	CR-94-L-0096-D CR-94-M-0028-D	SP-4200-2  445013	04 INSTALLED BY BYRD
310-1503-009 M94620  NEW	FAN, NO.5 ROOF EXHAUST	BYRD HARTZELL 70-60-AWN3 50000 CFM 1/4" SP		CR-94-L-0096-D CR-94-M-0033-D  2001-21-1	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-009M E94620 U62-11-3RA NEW	MOTOR, NO.5 ROOF EXHAUST FAN	TOSHIBA TEFC	5079 10 HP 1800 215T	CR-94-L-0096-D CR-94-M-0033-D	SP-4200-2  445013	04 INSTALLED BY BYRD
310-1503-010 M94621  NEW	FAN, NO.6 ROOF EXHAUST	BYRD HARTZELL 70-60-AWN3 5000 CFM 1/4" SP		CR-94-L-0096-D CR-94-M-0029-D  2001-21-1	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-010M E94621 U62-11-3RB NEW	MOTOR, NO.6 ROOF EXHAUST FAN	TOSHIBA TEFC	5080 10 HP 1800 215T	CR-94-L-0096-D CR-94-M-0029-D	SP-4200-2  445013	04 INSTALLED BY BYRD

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 107 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1503-014 M94625 NEW	FAN, NO.1 WALL EXHAUST	BYRD HARTZELL 09-60-LM3 45000 CFM 1/8" SP		CR-94-L-0096-D CR-94-M-0015-D  2001-21-2	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-014M E94625 U62-11-5RA NEW	MOTOR, NO.1 WALL EXHAUST FAN	TOSHIBA TEFC	5081 7.5 HP 1800 213T	CR-94-L-0096-D CR-94-M-0015-D	SP-4200-2  445013	04 INSTALLED BY BYRD
310-1503-015 M94626 NEW	FAN, NO.2 WALL EXHAUST	BYRD HARTZELL 09-60-LM3 45000 CFM 1/8" SP		CR-94-L-0096-D CR-94-M-0015-D  2001-21-2	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-015M E94626 U62-11-5RB NEW	MOTOR, NO.2 WALL EXHAUST FAN	TOSHIBA TEFC	5082 7.5 HP 1800 213T	CR-94-L-0096-D CR-94-M-0015-D	SP-4200-2  445013	04 INSTALLED BY BYRD
310-1503-016 M94627 NEW	FAN, NO.3 WALL EXHAUST	BYRD HARTZELL 09-60-LM3 45000 CFM 1/8" SP		CR-94-L-0096-D CR-94-M-0011-D  2001-21-2	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-016M E94627 U62-11-5RC NEW	MOTOR, NO.3 WALL EXHAUST FAN	TOSHIBA TEFC	5083 7.5 HP 1800 213T	CR-94-L-0096-D CR-94-M-0011-D	SP-4200-2  445013	04 INSTALLED BY BYRD
310-1503-017 M94628 NEW	FAN, NO.4 WALL EXHAUST	BYRD HARTZELL 09-60-LM3 45000 CFM 1/8" SP		CR-94-L-0096-D CR-94-M-0007-D  2001-21-2	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-017M E94628 U62-11-5RD NEW	MOTOR, NO.4 WALL EXHAUST FAN	TOSHIBA TEFC	5084 7.5 HP 1800 213T	CR-94-L-0096-D CR-94-M-0007-D	SP-4200-2  445013	04 INSTALLED BY BYRD

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 108 of 152
			Project no: AFCP-001 Document no: 990-01-0901


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-1503-018 M94629  NEW	FAN, NO.5 WALL EXHAUST	BYRD HARTZELL 09-60-LM3 45000 CFM 1/8" SP		CR-94-L-0096-D CR-94-M-0003-D  2001-21-2	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-018M E94629 U62-11-5RE NEW	MOTOR, NO.5 WALL EXHAUST FAN	TOSHIBA TEFC	5085 7.5 HP 1800 213T	CR-94-L-0096-D CR-94-M-0003-D	SP-4200-2  445013	04 INSTALLED BY BYRD
310-1503-030 M94640  NEW	HEATER, NO.1 STEAM UNIT	BYRD ARMSTRONG HUNT 3300 CFM NA11Q-161HS 188MBH		CR-94-L-0093-D CR-94-M-0015-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.431'-0" COL A-9
310-1503-030M E94640 U62-11-6RA NEW	MOTOR, NO.1 STEAM UNIT HEATER	BYRD	5869 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0015-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 431'-0" COL. A-9
310-1503-031 M94641  NEW	HEATER, NO.2 STEAM UNIT	BYRD ARMSTRONG HUNT 3300CFM NA11Q-161-HS 188MBH		CR-94-L-0096-D CR-94-M-0011-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.431'-0" COL. A-7
310-1503-031M E94641 U62-11-6RB NEW	MOTOR, NO.2 STEAM UNIT HEATER	BYRD	5870 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0011-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP EL. 431'-0" COL. A-7
310-1503-032 M94642  NEW	HEATER, NO.3 STEAM UNIT	BYRD ARMSTRONG HUNT 2600 CFM NA11Q-141-HS 147MBH		CR-94-L-0093-D CR-94-M-0007-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.431'-0" COL. A-5
310-1503-032M E94642 U62-11-7RA NEW	MOTOR, NO.3 STEAM UNIT HEATER	BYRD	5871 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0007-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 431'-0" COL. A-5

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 109 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1503-033 M94643  NEW	HEATER, NO.4 STEAM UNIT	BYRD ARMSTRONG HUNT 7000 CFM A11Q-241-HS 377 MBH		CR-94-L-0093-D CR-94-M-0003-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.431'-0" COL. B-3
310-1503-033M E94643 U62-11-7RC NEW	MOTOR, NO.4 STEAM UNIT HEATER	BYRD	5872 1.5 HP 1200 H145T	CR-94-L-0093-D CR-94-M-0003-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 431'-0" COL. B-3
310-1503-034 M94644  NEW	HEATER, NO.5 STEAM UNIT	BYRD ARMSTRONG HUNT 3300 CFM NA11Q-161-HS 188 MBH		CR-94-L-0093-D CR-94-M-0004-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.431'-0" COL. F-3
310-1503-034M E94644 U62-11-7RD NEW	MOTOR, NO.5 STEAM UNIT HEATER	BYRD	5873 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0004-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 431'-0" COL. F-E
310-1503-035 M94645  NEW	HEATER, NO.6 STEAM UNIT	BYRD ARMSTRONG HUNT 3300 CFM NA11Q-161-HS 188 MBH		CR-94-L-0093-D CR-94-M-0025-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.456'-0" COL. H-2
310-1503-035M E94645 U62-11-7RF NEW	MOTOR, NO.6 STEAM UNIT HEATER	BYRD	5874 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0025-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 456'-0" COL. H-2
310-1503-036 M94646	HEATER, NO.7 STEAM UNIT	BYRD ARMSTRONG HUNT 3300 CFM NA11Q-161-HS 188 MBH		CR-94-L-0093-D CR-94-M-0024-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.456'-0" COL. E-3
310-1503-036M E94646 U62-11-4RE NEW	MOTOR, NO.7 STEAM UNIT HEATER	BYRD	5875 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0024-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 456'-0" COL. E-3

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 110 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-1503-037 M94647  NEW	HEATER, NO.8 STEAM UNIT	BYRD ARMSTRONG HUNT 3300 CFM NA11Q-161-HS 188 MBH		CR-94-L-0093-D CR-94-M-0035-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.456'-0" COL. B-9
310-1503-037M E94647 U62-11-8FA	MOTOR, NO.8 STEAM UNIT HEATER	BYRD	5876 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0035-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 456'-0" COL. B-9
310-1503-038 M94648  NEW	HEATER, NO.9 STEAM UNIT	BYRD ARMSTRONG HUNT 2600 CFM NA11Q-141-HS 147 MBH		CR-94-L-0093-D CR-94-M-0037-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD EL.456'-0" COL.J-10
310-1503-038M E94648 U62-11-3RC NEW	MOTOR, NO.9 STEAM UNIT HEATER	BYRD	5877 0.5 HP 1800 56C	CR-94-L-0093-D CR-94-M-0037-D	SP-1501-1  445022	04 SUPPLIED WITH EQUIP. EL. 456'-0" COL J-10
310-1503-040 M94655 U62-11-9RFL NEW	HEATER, NO.1 ELECTRIC UNIT WEST STAIRWAY	BYRD TRANE CO. UHEC103DACA	10 KW (est) 1800	CR-94-L-0096-D CR-94-M-0015-D  2001-21-28	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-041 M94656 U62-11-9RFR NEW	HEATER, NO.2 ELECTRIC UNIT MCC H & V ROOM NO.1	BYRD TRANE CO. UHEC103DACA	10 KW (est) 1800	CR-94-L-0096-D CR-94-M-0015-D  2001-21-11	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-042 M94657 U62-11-8RDL NEW	HEATER, NO.3 ELECTRIC UNIT MCC H & V ROOM NO.2	BYRD TRANE CO. UHEC103DACA 10KW	10 KW (est) 1800	CR-94-L-0096-D CR-94-M-0017-D  2001-21-11	SP-1501-1  445022	06 INSTALLED BY BYRD
310-1503-050 M94670  NEW	PRESSURIZATION UNIT, RACK ROOM	BYRD PURAFIL TS-500F 500 CFM		CR-94-L-0095-D CR-94-M-0036-D  2001-21-12	SP-1501-1  445022	06 INSTALLED BY BYRD


 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 111 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02




EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-1503-050M E94670 U62-11-4RB NEW	MOTOR, RACK ROOM PRESSURIZATION UNIT	BYRD	5888 3 HP 1800 182T	CR-94-L-0095-D	SP-1501-1 445022	04 SUPPLIED WITH EQUIP.
310-1503-051 M94671  NEW	PRESSURIZATION UNIT, NO.1 MCC ROOM	BYRD PURAFIL TS-6000F 5500 CFM		CR-94-L-0094-D CR-94-M-0015-D  2001-21-11	SP-1501-1 445022	06 INSTALLED BY BYRD
310-1503-051M E94671 U62-11-4RC NEW	MOTOR, NO.1 MCC ROOM PRESSURIZATION UNIT	BYRD	5889 15 HP 1800 254T	CR-94-L-0094-D CR-94-M-0015-D	SP-1501-1 445022	04 SUPPLIED WITH EQUIP.
310-1503-052 M94672  NEW	PRESSURIZATION UNIT, NO.2 MCC ROOM	BYRD PURAFIL TS-6000F 5500 CFM		CR-94-L-0094-D CR-94-M-0017-D  2001-21-11	SP-1501-1 445022	06 INSTALLED BY BYRD
310-1503-052M E94672 U62-11-4RD NEW	MOTOR, NO.2 MCC ROOM PRESSURIZATION UNIT	BYRD	5890 15 HP 1800 254T	CR-94-L-0094-D CR-94-M-0017-D	SP-1501-1 445022	04 SUPPLIED WITH EQUIP.
310-1503-060 M94680 U62-11-8RDR NEW	COIL, CONF. ROOM ELECTRIC REHEAT	BYRD DELL CORP MODEL M-1 7KW	10 KW (est)	CR-94-L-0095-D	SP-1501-1 445022  2001-21-15	06 INSTALLED BY BYRD
310-1503-061 M94681 U62-11-8REL NEW	COIL, OFFICES ELECTRIC REHEAT OUTSIDE	BYRD DELL CORP MODEL M-1 7KW	10 KW (est)	CR-94-L-0095-D	SP-1501-1 445022  2001-21-15	06 INSTALLED BY BYRD
310-1503-062 M94682 U62-11-8RER NEW	COIL, CONTROL ROOM LABORATORY ELECTRIC REHEAT	BYRD DELL CORP MODEL M-1 12KW	12 KW (est)	CR-94-L-0095-D	SP-1501-1 445022  2001-21-13	06 INSTALLED BY BYRD

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 112 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-1503-063 M94683 U62-11-8RFL NEW	COIL, LOCKERS ELECTRIC REHEAT	BYRD DELL CORP MODEL M-1 7.5KW	7.5 KW (est)	CR-94-L-0095-D  2001-21-13	SP-1501-1 445022	06 INSTALLED BY BYRD
310-1503-064 M94684 U62-11-8RFR NEW	COIL, OFFICES ELECTRIC REHEAT INSIDE	BYRD DELL CORP MODEL M-1 10KW	10 KW (est)	CR-94-L-0095-D  2001-21-15	SP-1501-1 445022	06 INSTALLED BY BYRD
310-1503-070 M94685  NEW	HEATER, NO.1 ELECTRIC BASEBOARD	PETTY LINE	0.75 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-071 M94686  NEW	HEATER, NO.2 ELECTRIC BASEBOARD	PETTY LINE	0.75 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-072 M94687  NEW	HEATER, NO.3 ELECTRIC BASEBOARD	PETTY LINE	0.75 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-073 M94688  NEW	HEATER, NO.4 ELECTRIC BASEBOARD	PETTY LINE	0.75 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-074 M94689  NEW	HEATER, NO.5 ELECTRIC BASEBOARD	PETTY LINE	0.75 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-075 M94690  NEW	HEATER, NO.6 ELECTRIC BASEBOARD	PETTY LINE	0.75 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 113 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-1503-076 M94691  NEW	HEATER, NO.7 ELECTRIC BASEBOARD	PETTY LINE	1 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-077 M94692  NEW	HEATER, NO.8 ELECTRIC BASEBOARD	PETTY LINE	1 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-078 M94693  NEW	HEATER, NO.9 ELECTRIC BASEBOARD	PETTY LINE	1 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-079 M94694  NEW	HEATER, NO.10 ELECTRIC BASEBOARD	PETTY LINE	1 KW (est)	CR-94-E-0049-D	--- 445221	06 BY CONTRACTOR 208V
310-1503-901 M85115  EXISTING	UNIT, NO.1 BUILDING AIR MAKE-UP	BYRD TWIN CITY 730 BC ARR 3 CL 1 90 000 CFM 2. SP		CR-94-L-0093-D CR-94-M-0038-D  BC-10555	SP-1501-1 445022	04 INSTALLED BY BYRD
310-1503-901M E63380 U62-11-6FE EXISTING	MOTOR, NO.1 BUILDING AIR MAKE-UP UNIT	BYRD	5867 60 HP 1800	CR-94-L-0093-D CR-94-M-0038-D	SP-1501-1 445022	04 INSTALLED BY BYRD
310-1503-902 M85116  EXISTING	UNIT, NO.2 BUILDING AIR MAKE-UP	BYRD TWIN CITY 730 BC ARR 3 CL-1 90 000 CFM 2" SP		CR-94-L-0093-D CR-94-M-0038-D  BC-10555	SP-1501-1 445022	04 INSTALLED BY BYRD
310-1503-902M U62-11-5FE EXISTING	MOTOR, NO.2 BUILDING AIR MAKE-UP UNIT		5868 60 HP 1800	CR-94-L-0093-D CR-94-M-0038-D	--- 445022	04 INSTALLED BY BYRD

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 114 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-1533-001 M94590  NEW	PUMP, BIOCID	BY CHEMICAL SUPPLIER 110V POWER SUPPLY		CR-94-M-0003-D	---	06
310-1533-002 M94594  NEW	PUMP, NO.1 DEFOAMER	EGM, L.L.C. A&F DUPLEX 2860-2-55 MAX 17.0 GPM @ 500 PSI		CR-94-L-0047-D CR-94-M-0003-D	SP-1533-1 445073	06 3003
310-1533-002M E94594 U16-1B3-6RC1 NEW	MOTOR, NO.1 DEFOAMER	EGM, L.L.C. GENERAL ELECTRIC	5974 0.5 HP 1800 56C	CR-94-L-0047-D	SP-1533-1 445073	05 3003 110 V. DISCONNECTS 30 AMPS
310-1533-003 M94595  NEW	PUMP, NO.2 DEFOAMER	EGM, L.L.C. A&F DUPLEX 2860-2-55 MAX 17.0 GPM @ 500 PSI		CR-94-L-0047-D CR-94-M-0003-D	SP-1533-1 445073	06 3003
310-1533-003M E94595 U16-1B3-6RC2 NEW	MOTOR, NO.2 DEFOAMER PUMP	EGM, L.L.C. GENERAL ELECTRIC	5975 0.5 HP 1800 56C	CR-94-L-0047-D	SP-1533-1 445073	05 3003 110 V. DISCONNECTS 30 AMPS
310-1533-004 M94593  NEW	SKID, DEFOAMER	EGM, L.L.C.		CR-94-L-0047-D CR-94-M-0003-D	SP-1533-1 445073	06 3003
310-1533-006 M94548  NEW	SKID, NO.1 ANIONIC PUMPS	EGM, L.L.C.			SP-1533-1 445073	05
310-1533-007 M94549  NEW	SKID, NO.2 ANIONIC PUMPS	EGM, L.L.C.			SP-1533-1 445073	05

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 115 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-3520-001  NEW	EXPANSION JOINT, NO.1 PULPER DUMP CHEST TO SLUDGE CHEST OVERFLOW	BACHMANN DAMPJOINT  24" DIA. X 12" LONG 150#, 130F		CR-94-L-0056-D  2362-1	SP-3520-1  445049	06 CHEST INSERT M94040-15
310-3520-002  NEW	EXPANSION JOINT, NO.2 PULPER DUMP CHEST TO SLUDGE CHEST OVERFLOW	BACHMANN DAMPJOINT  24" DIA. X 12" LONG 150#, 130F		CR-94-L-0056-D  2362-1	SP-3520-1  445049	06 CHEST INSERT M94040-15
310-3520-003  NEW	EXPANSION JOINT, FLOTATION ACCEPTS TO PULPER DUMP CHEST OVERFLOW	BACHMANN DAMPJOINT  30" DIA. X 12" LONG 150#, 130F		CR-94-L-0056-D  2362-1	SP-3520-1  445049	06 CHEST INSERT M94040-25
310-3520-004  NEW	EXPANSION JOINT, NO.1 A-LINE DISC THICKENER CLOUDY WW	INDUSTRIAL RUBBER		CR-94-L-0076-D	SP-3520-1  445056	06
310-3520-005  NEW	EXPANSION JOINT, NO.2 A-LINE DISC THICKENER CLOUDY WW	INDUSTRIAL RUBBER		CR-94-L-0076-D	SP-3520-1  445056	06
310-3520-006  NEW	EXPANSION JOINT, NO.1 A-LINE DISC THICKENER CLEAR WW	INDUSTRIAL RUBBER		CR-94-L-0076-D	SP-3520-1  445056	06
310-3520-007  NEW	EXPANSION JOINT, NO.2 A-LINE DISC THICKENER CLEAR WW	INDUSTRIAL RUBBER		CR-94-L-0077-D	SP-3520-1  445056	06
310-3520-008  NEW	EXPANSION JOINT, NO.1 B-LINE DISC THICKENER CLOUDY WW	INDUSTRIAL RUBBER		CR-94-L-0077-D	SP-3520-1  445056	06

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 116 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-3520-009   NEW	EXPANSION JOINT, NO.2 B-LINE DISC THICKENER CLOUDY WW	INDUSTRIAL RUBBER		CR-94-L-0077-D	SP-3520-1  445056	06
310-3520-010   NEW	EXPANSION JOINT, NO.1 B-LINE DISC THICKENER CLEAR WW	INDUSTRIAL RUBBER		CR-94-L-0077-D	SP-3520-1  445056	06
310-3520-011   NEW	EXPANSION JOINT, NO.2 B-LINE DISC THICKENER CLEAR WW	INDUSTRIAL RUBBER		CR-94-L-0077-D	SP-3520-1  445056	06
310-3550-001   NEW	SAFETY SHOWER, RAIL CAR UNLOADING AREA	ENCON 330A0000100		CR-94-L-0040-D KW (est) CR-94-M-0057-D	SP-3550-1  445074	06 3003 HEAT TRACED
310-3550-002   NEW	SAFETY SHOWER, TANK TRUCK UNLOADING AREA	ENCON 330A0000100		CR-94-L-0041-D KW (est) CR-94-M-0057-D	SP-3550-1  445074	06 3003 HEAT TRACED
310-3550-004   NEW	SAFETY SHOWER, SODIUM SILICATE AND SODIUM HYDROXIDE CONTAINMENT AREA	ENCON 330A0000100		CR-94-L-0043-D KW (est) CR-94-M-0057-D	SP-3550-1  445074	06 3003 HEAT TRACED
310-3550-005   NEW	SAFETY SHOWER, POLYMER CONTAINMENT AREA	ENCON 330A0000100		CR-94-L-0044-D KW (est) CR-94-M-0057-D	SP-3550-1  445074	06 3003 HEAT TRACED
310-3550-006   NEW	SAFETY SHOWER, PEROXIDE CONTAINMENT AREA	ENCON 330A0000100		CR-94-L-0046-D KW (est) CR-94-M-0057-D	SP-3550-1  445074	06 3003 HEAT TRACED

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 117 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02




EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-3550-007  NEW	SAFETY SHOWER, DEFOAMER TANK AREA	ENCON D1932		CR-94-L-0047-D CR-94-M-0007-D  D1932	SP-3550-1  445074	06 3003
310-3550-008  NEW	SAFETY SHOWER, GROUND FLOOR NORTH EAST	ENCON D1932		CR-94-L-0085-D CR-94-M-0017-D  D1932	SP-3550-1  445074	06 3003
310-3550-009  NEW	SAFETY SHOWER, LABORATORY	ENCON VERTICAL VALVE 01-0401-23		CR-94-L-0085-D CR-94-M-0035-D  01-0401-23	SP-3550-1  445074	06 3003 BENCH MOUNTED
310-3550-010  NEW	SAFETY SHOWER, DISC THICKENER PLATFORM	ENCON D1932		CR-94-L-0076-D CR-94-M-0031-D  D1932	SP-3550-1  445074	06 3003
310-3550-011  NEW	SAFETY SHOWER, OPERATING FLOOR MAINTENANCE AREA	ENCON D1932		CR-94-L-0085-D CR-94-M-0037-D  D1932	SP-3550-1  445074	06 3003
310-3550-012  NEW	SAFETY SHOWER, OPERATING FLOOR SOUTH SIDE	ENCON D1932		CR-94-L-0085-D CR-94-M-0025-D  D1932	SP-3550-1  445074	06 3003
310-3550-013  NEW	SAFETY SHOWER, PULPERS AREA	ENCON 330A0000100		CR-94-L-0053-D KW (est) CR-94-M-0059-D  330A0000100	SP-3550-1  445074	06 3003 HEAT TRACED
310-4104-001 S62  NEW	SWITCH, OUTDOOR BREAK	GE CANADA AIDUTI-RUPTER POLE MOUNTED SWITCH 600 AMPS		300-04-0025	SP-4100-1  445018	06

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 118 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-4120-100 M94801  NEW	3500A CABLE BUS DUCT, NO.1 5KV A-LINE	MP HUSKY  3500A, 5KV		CR-94-E-0055-D  01946-101	SP-4120-1  445035	06 4001
310-4120-200 M94802  NEW	3500A CABLE BUS DUCT, NO.2 5KV B-LINE	MP HUSKY  3500A, 5KV		CR-94-E-0055-D  01946-101	SP-4120-1  445035	06 4001
310-4120-300 M94803  NEW	5000A CABLE BUS DUCT, NO.3 600V A-LINE	MP HUSKY  5000A, 600V		CR-94-E-0055-D  01946-102	SP-4120-1  445035	06 4001
310-4120-400 M94804  NEW	5000A CABLE BUS DUCT, NO.4 600V B-LINE	MP HUSKY  5000A, 600V		CR-94-E-0055-D  01946-102	SP-4120-1  445035	06 4001
310-4120-500 M94805  NEW	3000A CABLE BUS DUCT, NO.5 600V A-LINE VFD	MP HUSKY  3000A, 600V		CR-94-E-0055-D  01946-102	SP-4120-1  445035	06 4001
310-4120-600 M94806  NEW	3000A CABLE BUS DUCT, NO.6 600V B-LINE VFD	MP HUSKY  3000A, 600V		CR-94-E-0055-D  01946-102	SP-4120-1  445035	06 4001
310-4120-700 M94807  NEW	2000A CABLE BUS DUCT, NO.7 600V UTILITY	MP HUSKY  2000A, 600V		CR-94-E-0055-D  01946-101	SP-4120-1  445035	06 4001
310-4130-100 SG-16  NEW	15 KV SWITCHGEAR	GE CANADA  108"L X 94"W X 95"H S.O. 979479		CR-94-E-0055-D  0202D4800	SP-4130-1  445018	06 4001

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 119 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-4130-200 S16-1A  NEW	5 KV SWITCHGEAR, NO.1 FOR A-LINE 2.3 KV STARTER LINE-UPS	GE CANADA  108"L X 106"W X 95"H S.O. 979478		CR-94-E-0055-D  0202D4799	SP-4140-1  445018	06 4001
310-4130-300 S16-2C  NEW	5 KV SWITCHGEAR, NO.2 FOR B-LINE 2.3 KV STARTER LINE-UPS	GE CANADA  108"L X 106"W X 95"H S.O. 979478		CR-94-E-0055-D  0202D4799	SP-4140-1  445018	05 4001
310-4130-400 U16-1B  NEW	600 V SWITCHGEAR, NO.1 FOR A-LINE 480 V MCCS	GE CANADA  70" L X 74"W X 94"H		CR-94-E-0055-D  0199D7972	SP-4140-2  445018	06 4001
310-4130-500 U16-2A  NEW	600 V SWITCHGEAR, NO.2 FOR B-LINE 480 V MCCS	GE CANADA  70"L X 74"W X 94"H		CR-94-E-0055-D  0199D7972	SP-4140-2  445018	06 4001
310-4130-600 C16-3  NEW	CAPACITOR FILTER BANK	GE CANADA		CR-94-E-0055-D  49291	SP-4130-1  445018	06 4001
310-4134-100 M94811  NEW	BATTERY SYSTEM FOR 15 KV SWITCHGEAR	GE CANADA PRIMAX TECH.		CR-94-E-0055-D  B633	SP-4130-1  445018	08 4001
310-4140-100 IR16-1A  NEW	15 KV LOAD BREAK SWITCH FOR 10 MVA TRF A-LINE	GE CANADA		CR-94-E-0055-D	SP-4140-1  445018	06 4001
310-4140-101 TR16-1A  NEW	TRANSFORMER, 10 MVA 11.5 KV / 2.3 KV A-LINE	GE CANADA  S/N P1054747-475		CR-94-E-0055-D  4241200B0774	SP-4140-1  445018 452600 LBS	05 4001

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 120 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-4140-102  NEW	NEUTRAL GROUNDING RESISTOR HIGH RESISTANCE FOR 10 MVA TRF A-LINE	GE CANADA		CR-94-E-0055-D	SP-4140-1 445018	06 4001
310-4140-200 IR16-2C  NEW	15 KV LOAD BREAK SWITCH FOR 10 MVA TRF B-LINE	GE CANADA		CR-94-E-0055-D	SP-4140-1 445018	06 4001
310-4140-201 TR16-2C  NEW	TRANSFORMER, 10 MVA 11.5 KV / 2.3 KV B-LINE	GE CANADA		CR-94-E-0055-D 4241200B0774	SP-4140-1 445018 45260 LBS	05 4001
310-4140-202  NEW	NEUTRAL GROUNDING RESISTOR HIGH RESISTANCE FOR 10 MVA TRF B-LINE	GE CANADA S/N P105474-475		CR-94-E-0055-D	SP-4140-2 445018	06 4001
310-4140-300 IR16-1B  NEW	15 KV LOAD BREAK SWITCH FOR 2.5 MVA TRF A-LINE	GE CANADA		CR-94-E-0055-D	SP-4140-2 445018	06 4001
310-4140-301 TR16-1B  NEW	TRANSFORMER, 2.5 MVA 11.5 KV/480 V A-LINE	GE CANADA		CR-94-E-0055-D 4241200B0772	SP-4140-2 445018 16065 LBS	05 4001
310-4140-302  NEW	NEUTRAL GROUNDING RESISTOR HIGH RESISTANCE FOR 2.5 MVA TRF A-LINE	GE CANADA		CR-94-E-0055-D	SP-4140-2 445018	05 4001
310-4140-400 IR16-2A  NEW	15 KV LOAD BREAK SWITCH FOR 2.5 MVA TRF B-LINE	GE CANADA		CR-94-E-0055-D	SP-4140-2 445018	06 4001


 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 121 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO	DESCRIPTION	MANUFACTURER	MOTOR NO	P/I DIAGRAM	SPEC. NO	REVISION
CLIENT NO		MODEL	RATED POWER	EQ.LAY.DWG	B/M NO	
CIRCUIT NO		SIZE	RPM	FOUND.DWG	P.O. NO	
STATUS		RATING	FRAME	MFR. DWG	WEIGHT	REMARKS
310-4140-401 TR16-2A	TRANSFORMER, 2.5 MVA 11.5 KV/480 V B-LINE	GE CANADA			SP-4140-2	05
				CR-94-E-0055-D	445018	4001
NEW		S/N P105471-472		4241200B0772	16065 LBS	
310-4140-402	NEUTRAL GROUNDING RESISTOR HIGH RESISTANCE FOR 2.5 MVA TRF B-LINE	GE CANADA			SP-4140-2	06
				CR-94-E-0055-D	445018	4001
NEW						
310-4140-500 IR16-1C	15 KV LOAD BREAK SWITCH FOR 1.5 MVA TRF. - VFD LINE-UP (A-LINE)	GE CANADA			SP-4140-2	06
				CR-94-E-0055-D	445018	4001
NEW						
310-4140-501 TR16-1C	TRANSFORMER, 1.5 MVA 11.5 KV/480 V - VFD (A-LINE)	GE CANADA			SP-4140-2	05
				CR-94-E-0055-D	445018	4001
NEW		S/N P105482-483		4241200B0773	10545 LBS	
310-4140-502	NEUTRAL GROUNDING RESISTOR HIGH RESISTANCE FOR 1.5. MVA TRF VFD (A-LINE)	GE CANADA			SP-4140-2	05
				CR-94-E-0055-D	445018	4001
NEW						
310-4140-600 IR-62	15 KV LOAD BREAK SWITCH FOR 1.5 MVA TRF UTILITY	GE CANADA			SP-4140-2	05
				CR-94-E-0055-D	445018	4001
NEW						
310-4140-601 TR-62	TRANSFORMER, 1.5 MVA 11.5 KV/480 V - UTILITY	GE CANADA			SP-4140-2	05
				CR-94-E-0055-D	445018	4001
NEW		S/N P105476		4241200B0775	10585 LBS	
310-4140-700	15 KV LOAD BREAK SWITCH 10MVA TRF - FUTURE	GE CANADA			SP-4140-1	05
				CR-94-E-0055-D	445018	4001
FUTURE						

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. ENVIRONMENTAL AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 122 of 152
			Revision: 08
			Date: 5/21/02
		Project no: AFCP-001 Document no: 990-01-0901	



EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-4140-701   FUTURE	TRANSFORMER 10 MVA 11.5 KV/2.3 KV - FUTURE	GE CANADA			SP-4140-1 CR-94-E-0055-D 445018	05 4001
310-4140-702   FUTURE	NEUTRAL GROUNDING RESISTOR HIGH RESISTANCE FOR 10 MVA TRF	GE CANADA			SP-4140-1 CR-94-E-0055-D 445018	05 4001
310-4140-800 IR16-2B  NEW	15 KV LOAD BREAK SWITCH FOR 1.5 MVA TKF - VFD LINE-UP (B-LINE)	GE CANADA			SP-4140-2 CR-94-E-0055-D 445018	05 4001
310-4140-801 TR16-2B  NEW	TRANSFORMER, 1.5 MVA 11.5 KV / 480 V - VFD (B-LINE)	GE CANADA			SP-4140-2 CR-94-E-0055-D 445018 4241200B0773 10545 LBS	05 4001
310-4140-802   NEW	NEUTRAL GROUNDING RESISTOR HIGH RESISTANCE FOR 1.5 MVA TRF VFD (B-LINE)	GE CANADA S/N P105482-483			SP-4140-2 CR-94-E-0055-D 445018	05 4001
310-4165-100 94-UPS-01  NEW	UNIT, UNINTERRUPTABLE POWER SUPPLY	MAJOR POWER AXXIUM PRO 0650  15 KVA			CR-94-E-0055-D BM-310-4150-001 445077	05 4001
310-4250-002 D94330  NEW	DRIVE, A-LINE DISC THICKENER VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0076-D CR-94-M-0031-D	SP-4250-1 445023	06 4001
310-4250-003 D94340  NEW	DRIVE, B-LINE DISC THICKENER VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0077-D CR-94-M-0031-D	SP-4250-1 445023	06 4001

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 123 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02



EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-4250-004 D94360  NEW	DRIVE, NO.1 A-LINE SCREW PRESS VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0079-D CR-94-M-0027-D	SP-4250-1  445023	06 4001
310-4250-005 D94365  NEW	DRIVE, NO.2 A-LINE SCREW PRESS VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0079-D CR-94-M-0025-D	SP-4250-1  445023	06 4001
310-4250-006 D94370  NEW	DRIVE, NO.1 B-LINE SCREW PRESS VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0080-D CR-94-M-0023-D	SP-4250-1  445023	06 4001
310-4250-007 D94375  NEW	DRIVE, NO.2 B-LINE SCREW PRESS VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0080-D CR-94-M-0023-D	SP-4250-1  445023	06 4001
310-4250-008 D94502  NEW	DRIVE, A-LINE SODIUM HYDROXIDE PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0040-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-009 D94504  NEW	DRIVE, B-LINE SODIUM HYDROXIDE PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0040-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-010 D94512  NEW	DRIVE, A-LINE SURFACTANT METERING PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0041-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-011 D94514  NEW	DRIVE, B-LINE SURFACTANT METERING PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0041-D CR-94-M-0057-D	SP-4250-1  445023	06 4001

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 124 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-4250-014 D94532  NEW	DRIVE, A-LINE SODIUM SILICATE PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0043-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-015 D94534  NEW	DRIVE, B-LINE SODIUM SILICATE PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0043-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-016 D94542  NEW	DRIVE, NO.1 CATIONIC POLYMER METERING PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0044-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-017 D94545  NEW	DRIVE, NO.2 CATIONIC POLYMER METERING PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0044-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-019 D94564  NEW	DRIVE, A-LINE ANIONIC POLYMER METERING PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0045-D 310-010057	SP-4250-1  445023	06 4001
310-4250-020 D94567  NEW	DRIVE, B-LINE ANIONIC POLYMER METERING PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0045-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-021 D94582  NEW	DRIVE, A-LINE HYDROGEN PEROXIDE PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0046-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-022 D94584  NEW	DRIVE, B-LINE HYDROGEN PEROXIDE PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0046-D CR-94-M-0057-D	SP-4250-1  445023	06 4001

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 125 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-4250-025 D94380  NEW	DRIVE, RECYCLED PULP CONVEYOR VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0080-D	SP-4250-1  445023	06 4001
310-4250-030 D94507  NEW	DRIVE, SODIUM HYDROXIDE METERING STANDBY PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0040-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-031 D94516  NEW	DRIVE, SURFACTANT METERING STANDBY PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0041-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-032 D94537  NEW	DRIVE, SODIUM SILICATE METERING STANDBY PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0043-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-033 D94587  NEW	DRIVE, HYDROGEN PEROXIDE STANDBY PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0046-D CR-94-M-0057-D	SP-4250-1  445023	06 4001
310-4250-035 D94446  NEW	DRIVE, NO.1 PROCESS U-DRAIN SUMP PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0090-D 310-01-0055	SP-4250-1  445023	06 4001
310-4250-036 D94447  NEW	DRIVE, NO.2 PROCESS U-DRAIN SUMP PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-94-L-0090-D 310-01-0055	SP-4250-1  445023	06 4001
310-4256-100 U16-1C  NEW	VARIABLE FREQUENCY DRIVE LINE-UP NO.1 A-LINE	MATTHEWS ELECTRIC ALLEN BRADLEY  600 V		CR-94-E-0055-D  C-XVK130-0001	SP-4250-1  445023	06 4001

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 126 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-4256-200 U16-2B  NEW	VARIABLE FREQUENCY DRIVE LINE-UP NO.2 B-LINE	MATTHEWS ELECTRIC ALLEN BRADLEY  600 V		CR-94-E-0055-D  C-XVK130-0001	SP-4250-1  445023	06 4001
310-4305-100 S16-1A1  NEW	MOTOR CONTROL CENTER - 2.3 KV STARTER LINE-UP NO.1 (A-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 198"L X 30"W X 93.75"H		CR-94-E-0055-D  7003241-001-01D	SP-4300-1  445023 14760 LBS	05 4001
310-4305-200 S16-1A2  NEW	MOTOR CONTROL CENTER - 2.3 KV STARTER LINE-UP NO.2 (A-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 198"L X 30"W X 93.75"H		CR-94-E-0055-D  7003241-002-01D	SP-4300-1  445023 11220 LBS.	05 4001
310-4305-300 S16-2C1  NEW	MOTOR CONTROL CENTER, 2.3 KV STARTER LINE-UP NO.3 (B-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 198"L X 30"W X 93.75"H		CR-94-E-0055-D  7003241-003-01D	SP-4300-1  445023 12990 LBS	05 4001
310-4305-400 S16-2C2  NEW	MOTOR CONTROL CENTER, 2.3 KV STARTER LINE-UP NO.4(B-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 198"L X 30"W X 93.75"H		CR-94-E-0055-D  7003241-004-01D	SP-4300-1  445023 11220 LBS.	05 4001
310-4310-100 U16-1B1  NEW	MOTOR CONTROL CENTER, 480V MCC NO.1 (A-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 140"L X 30"W X 90"H S/N 2100-HXYZ705/01		CR-94-E-0055-D  2100-HXYZ705/01	SP-4310-1  445023 8400 LBS	06 4001
310-4310-200 U16-1B2  NEW	MOTOR CONTROL CENTER, 480 V MCC NO.2 (A-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 100"L X 30"W X 90"H S/N 2100-HXYZ705/02		CR-94-E-0055-D  2100-HXYZ705/02	SP-4310-1  445023 6000 LBS	06 4001
310-4310-300 U16-1B3  NEW	MOTOR CONTROL CENTER, 480 V MCC NO.3 (COMMON)	MATTHEWS ELECTRIC ALLEN BRADLEY 140"L X 30"W X 90"H S/N 2100-HXYZ705/03		CR-94-E-0055-D  2100-HXYZ705/03	SP-4310-1  445023 8400 LBS	06 4001

 <b>AJAMI, BEDARD, GAGNON, SEXTON INC.</b> PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 127 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-4310-400 U16-2A1  NEW	MOTOR CONTROL CENTER, 480 V MCC NO.5 (B-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 140"L X 30"W X 90"H S/N 2100-HXYZ705/04		CR-94-E-0055-D  2100-HXYZ705/04	SP-4310-1  445023 8400 LBS	06 4001
310-4310-500 U16-2A2  NEW	MOTOR CONTROL CENTER, 480 V MCC NO.6 (B-LINE)	MATTHEWS ELECTRIC ALLEN BRADLEY 100"L X 30"W X 90"H S/N 2100-HXYZ705/05		CR-94-E-0055-D  2100-HXYZ705/05	SP-4310-1  445023 6000 LBS	06 4001
310-4310-900 U62-11  NEW	MOTOR CONTROL CENTER, 480 V MCC NO.9 - UTILITY	MATTHEWS ELECTRIC ALLEN BRADLEY 190"L X 40"W X 90"H S/N 2100-HXYZ705/06		CR-94-E-0055-D  2100-HXYZ705/06	SP-4310-1  445023 10800 LBS	06 4001
310-4315-001 ATS-1B3  NEW	SWITCH, AUTOMATIC TRANSFER TO FEED MCC U16-1B3	MAYER ELECTRIC ASCO POWER  1200 AMPS		CR-94-E-0055-D  617409	SP-4310-1  445048	06 4001
310-4315-002 ATS-2A4  NEW	SWITCH, AUTOMATIC TRANSFER TO FEED MCC U16-2A4	MAYER ELECTRIC ASCO POWER  1200 AMPS		CR-94-E-0055-D  617409	SP-4310-1  445048	06 4001
310-4315-003 ATS-LP-B  NEW	SWITCH, AUTOMATIC TRANSFER	MAYER ELECTRIC ASCO POWER  100A		CR-94-E-0055-D  617406	SP-4310-1  445048	06 4101
310-4315-004 ATS-LP-E  NEW	SWITCH, AUTOMATIC TRANSFER	MAYER ELECTRIC ASCO POWER  100A		CR-94-E-0055-D  617406	SP-4310-1  445048	06 4101
310-4330-002 M94458  NEW	PANEL, MILL AIR DRYER CONTROL	GENERAL MACHINERY ALLEN BRADLEY  SKID MOUNTED	0.25 HP (est)	CR-94-L-0086-D CR-94-M-0013-D  230376	SP-1217-1  445037	06 4001 3002 40 AMP DISCONNECT

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 128 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-4330-010 M94363  NEW	PANEL, NO.1 A-LINE SCREW PRESS PNEUMATIC CONTROL	KVAERNER		CR-94-L-0079-D CR-94-M-0027-D  E-017017	SP-1214-1  445005	06 STAND MOUNTED 6000
310-4330-011 M94368  NEW	PANEL, NO.2 A-LINE SCREW PRESS PNEUMATIC CONTROL	KVAERNER		CR-94-L-0079-D CR-94-M-0027-D  E-017017	SP-1214-1  445005	06 STAND MOUNTED 6000
310-4330-012 M94373  NEW	PANEL, NO.1 B-LINE SCREW PRESS PNEUMATIC CONTROL	KVAERNER		CR-94-L-0080-D CR-94-M-0023-D  E-017017	SP-1214-1  445005	06 STAND MOUNTED 6000
310-4330-013 M94378  NEW	PANEL, NO.2 B-LINE SCREW PRESS PNEUMATIC CONTROL	KVAERNER		CR-94-L-0080-D CR-94-M-0023-D  E-017017	SP-1214-1  445005	06 STAND MOUNTED 6000
310-4330-014 M94552  NEW	PANEL, NO.1 ANIONIC EMULSIFIER SYSTEM CONTROL	EGM, L.L.C.		CR-94-I-0043-D  L6655-0B	SP-1533-1  445073	06 C/W STARTERS 30 AMP DISCONNECT
310-4330-015 M94559  NEW	PANEL, NO.2 ANIONIC EMULSIFIER SYSTEM CONTROL	EGM, L.L.C.		CR-94-I-0043-D  L6655-0C	SP-1533-1  445073	06 C/W STARTERS 30 AMP DISCONNECT
310-4330-016 M94565  NEW	PANEL, DEFOAMER SYSTEM CONTROL	EGM, L.L.C.		CR-94-I-0041-D  58012L	SP-1533-1  445073	06 C/W STARTER 30 AMP DISCONNECT
310-4330-017 M94383  NEW	PANEL, RECYCLED PULP DIVERTING SCREW CONVEYOR CONTROL	HAMMOND		CR-94-L-0079-D  CR-94-E-0134 B	---	08

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 129 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02



EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-4360-100 94-PLC/A-01  NEW	CABINET, NO.1 A-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000
310-4360-101 94-PLC/A-02  NEW	CABINET, NO.2 A-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000
310-4360-102 94-PLC/A-03  NEW	CABINET, NO.3 A-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000
310-4360-103 94-PLC/A-04  NEW	CABINET, NO.4 A-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000
310-4360-200 94-PLC/B-01  NEW	CABINET, NO.1 B-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000
310-4360-201 94-PLC/B-02  NEW	CABINET, NO.2 B-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000
310-4360-202 94-PLC/B-03  NEW	CABINET, NO.3 B-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000
310-4360-203 94-PLC/B-04  NEW	CABINET, NO.4 B-LINE PLC FLEX I/O	LAURENTIDE CONTROLS		CR-94-I-0045-D	SP-4300-1 445016	05 6000 CHEMICAL AREA

 <b>AJAMI, BEDARD, GAGNON, SEXTON INC.</b> PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT  PROCESS BUILDING	Page: 130 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-4360-300 94-PLC/C-01  NEW	CABINET, NO.1 COMMON FLEX I/O	LAURENTIDE CONTROLS			SP-4300-1 CR-94-I-0045-D 445016	05 6000
310-4360-301 94-PLC/C-02  NEW	CABINET, NO.2 COMMON FLEX I/O	LAURENTIDE CONTROLS			SP-4300-1 CR-94-I-0045-D 445016	05 6000
310-4360-400 94-PLC/A  NEW	PLC, A-LINE	LAURENTIDE CONTROLS			SP-4300-1 CR-94-I-0045-D 445016	05 6000
310-4360-401 94-PLC/B  NEW	PLC, B-LINE	LAURENTIDE CONTROLS			SP-4300-1 CR-94-I-0045-D 445016	05 6000
310-4360-402 94-PLC/C  NEW	PLC, COMMON	LAURENTIDE CONTROLS			SP-4300-1 CR-94-I-0045-D 445016	05 6000
310-4360-403 94-PLC/CPU  NEW	CABINET, PLC CPU	LAURENTIDE CONTROLS			SP-4300-1 CR-94-I-0045-D 445016	07
310-4440-001 M94501  NEW	HEATER, SODIUM HYDROXIDE STORAGE TANK ELECTRIC	HEAT TRACE 13-EGLX PANELS  240 V/28A	6.5 KW (est)	CR-94-L-0040-D CR-94-M-0057-D  D-297	SP-4440-1 445067	05 4002
310-4440-002 M94511  NEW	HEATER, SURFACTANT STORAGE TANK ELECTRIC	HEAT TRACE 8-EGLX PANELS  240V/17A	6.5 KW (est)	CR-94-L-0041-D CR-94-M-0057-D  D-297	SP-4440-1 445067	05 4002

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 131 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION   REMARKS
310-4440-003 M94531  NEW	HEATER, SODIUM SILICATE STORAGE TANK ELECTRIC	HEAT TRACE 16-EGLX PANELS 8.0 KW 240 V/34A	8 KW (est)	CR-94-L-0043-D CR-94-M-0057-D  D-298	SP-4440-1  445067	05 4002
310-4440-004 M94541  NEW	HEATER, CATIONIC POLYMER STORAGE TANK ELECTRIC	HEAT TRACE 5-EGLX PANELS 3.0 KW 240 V/11A	3 KW (est)	CR-94-L-0044-D CR-94-M-0057-D  D-293	SP-4440-1  445067	05 4002
310-4440-005 M94551  NEW	HEATER, ANIONIC POLYMER STORAGE TANK ELECTRIC	HEAT TRACE 5-EGLX PANELS 3.0 KW 240 V/11A	3 KW (est)	CR-94-L-0045-D CR-94-M-0057-D  D-294	SP-4440-1  445067	05 4002
310-4440-006 M94571  NEW	HEATER, ANIONIC POLYMER AGING TANK ELECTRIC	HEAT TRACE 5-EGLX PANLES 2.5 KW 240V/11A	2.5 KW (est)	CR-94-L-0045-D CR-94-M-0057-D  D-295	SP-4440-1  445067	05 4002
310-4440-007 M94572  FUTURE	HEATER, ANIONIC POLYMER AGING TANK ELECTRIC (FUTURE)			CR-94-L-0045-D CR-94-M-0057-D  D-295	---  ---	05
310-5300-001 M94495  NEW	DOOR, WEST ELECTRIC	BRASFIELD & GORRIE ALBANY DOOR # 670 14"W X 16"H		CR-94-S-0261-D  670-0001	---  445213	06 5002 INSTALLED BY CONTRACTOR
310-5300-001M E94495 U62-11-9FCL NEW	MOTOR, WEST ELECTRIC DOOR	BRASFIELD & GORRIE	1.25 HP (est) 140 145TC	CR-94-E-0067-D	---  445213	06 5002 BRASFIELD & GORRIE
310-6410-001 WS-01  NEW	WORKSTATION, NO.1 DCS	LAURENTIDE CONTROLS		CR-94-I-0045-D	---  445016	07 6000 MODEL & SIZE DELETED

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 132 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-6410-002 WS-02  NEW	WORKSTATION, NO.2 DCS	LAURENTIDE CONTROLS		CR-94-I-0045-D	---  445016	07 6000 MODEL & SIZE DELETED
310-6410-003 WS-03  NEW	WORKSTATION, NO.3 DCS	LAURENTIDE CONTROLS		CR-94-I-0045-D	---  445016	07 6000 MODEL & SIZE DELETED
310-6410-004 WS-04  NEW	WORKSTATION, NO.4 DCS	LAURENTIDE CONTROLS		CR-94-I-0045-D	---  445016	07 6000 MODEL & SIZE DELETED
310-6410-005  NEW	WORKSTATION, ENGINEERING DCS	LAURENTIDE CONTROLS		CR-94-I-0045-D	---  445016	06 6000
310-6410-006  NEW	WORKSTATION, ENGINEERING PLC	LAURENTIDE CONTROLS		CR-94-I-0045-D	---  445016	06 6000
310-6410-007  NEW	CABINET, NO.1 A-LINE DCS	LAURENTIDE CONTROLS DELTA-V CABINET 88" X 40" X 24" FREE STANDING		CR-94-I-0045-D	  445016	07
310-6410-008  NEW	CABINET, NO.2 B-LINE DCS	LAURENTIDE CONTROLS DELTA-V CABINET 88" X 40" X 24" FREE STANDING		CR-94-I-0045-D	  445016	07
310-6410-009  NEW	CABINET, NO. 3 COMMON DCS	LAURENTIDE CONTROLS DELTA-V CABINET 88" X 40" X 24" FREE STANDING		CR-94-I-0045-D	  445016	07

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Project no: AFCP-001	Page: 133 of 152
			Document no: 990-01-0901	Revision: 08  Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-6540-001 94-JBA-01  NEW	JUNCTION BOX, NO.1 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0015		
310-6540-002 94-JBA-02  NEW	JUNCTION BOX, NO.2 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0016		
310-6540-003 94-JBA-03  NEW	JUNCTION BOX, NO.3 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0017		
310-6540-004 94-JBA-04  NEW	JUNCTION BOX, NO.4 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0018		
310-6540-005 94-JBA-05  NEW	JUNCTION BOX, NO.5 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0019		
310-6540-006 94-JBA-06  NEW	JUNCTION BOX, NO.6 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0020		
310-6540-007 94-JBA-07  NEW	JUNCTION BOX, NO.7 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0021		
310-6540-008 94-JBA-08  NEW	JUNCTION BOX, NO.8 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0022		

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT PROCESS BUILDING	Page: 134 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
310-6540-009 94-JBA-09  NEW	JUNCTION BOX, NO.9 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0023		
310-6540-010 94-JBA-10  NEW	JUNCTION BOX, NO.10 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0024		
310-6540-011 94-JBA-11  NEW	JUNCTION BOX, NO.11 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0025		
310-6540-012 94-JBA-12  NEW	JUNCTION BOX, NO.12 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0026		
310-6540-013 94-JBA-13  NEW	JUNCTION BOX, NO.13 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0027		
310-6540-014 94-JBA-14  NEW	JUNCTION BOX, NO.14 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0028		
310-6540-015 94-JBA-15  NEW	JUNCTION BOX, NO.15 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0029		
310-6540-016 94-JBA-16  NEW	JUNCTION BOX, NO.16 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS  24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0030		


 <b>AJAMI, BEDARD, GAGNON, SEXTON INC.</b> PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310 RECYCLE FIBER PLANT PROCESS BUILDING	Page: 135 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02




EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
310-6540-017 94-JBA-17 NEW	JUNCTION BOX, NO.17 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0031		
310-6540-018 94-JBA-18 NEW	JUNCTION BOX, NO.18 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0032		
310-6540-019 94-JBA-19 NEW	JUNCTION BOX, NO. 19 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0033		
310-6540-020 94-JBA-20 NEW	JUNCTION BOX, NO.20 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0034		
310-6540-021 94-JBA-21 NEW	JUNCTION BOX, NO.21 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0035		
310-6540-022 94-JBA-22 NEW	JUNCTION BOX, NO.22 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0036		
310-6540-023 94-JBA-23 NEW	JUNCTION BOX, NO.23 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0037		
310-6540-024 94-JBA-24 NEW	JUNCTION BOX, NO.24 INSTRUMENTATION ANALOG	LAURENTIDE CONTROLS 24" X 24" X 12"			--- --- 445016	05 6000
				310-06-0038		

 <b>AJAMI, BEDARD, GAGNON, SEXTON INC.</b> PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 310  RECYCLE FIBER PLANT  PROCESS BUILDING	Page: 136 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1100-001 M41170 U5305/5408-2FBL NEW	HOIST, RECYCLED PULP DILUTION CONVEYOR	CRANE PRO SERVICES XL 302 HOIST 131 FT. LIFT 3.5 TON CAP.		CR-20-L-0180-D CR-20-M-0280-D  DP30200NAF	SP-1101-2  445070	05 INSTALLED BY CONTINENTAL ONE POWER SUPPLY
950-1100-001M E41170 HOIST20-01 NEW	MOTOR, NO.1 RECYCLED PULP DILUTION CONVEYOR HOIST	CRANE PRO SERVICES	5979 12 HP 3600/600	CR-20-L-0180-D CR-20-M-0280-D	SP-1101-2  445070	05 INSTALLED BY CONTINENTAL
950-1100-002M E41172 HOIST20-02 NEW	MOTOR, NO.2 RECYCLED PULP DILUTION CONVEYOR HOIST	CRANE PRO SERVICES	5980 0.54 HP 3600/600	CR-20-L-0180-D CR-20-M-0280-D	SP-1101-2  445070	05 INSTALLED BY CONTINENTAL
950-1123-001 M41169 NEW	CONVEYOR, RECYCLED PULP DILUTION	CONTINENTAL / TGS SCREW TYPE, 60 RPM DIA. 36" x 24'-8 1/4" L 1700 BDSTPD, 12 - 14%		CR-20-L-0180-D CR-20-M-0280-D  TD-122-217D	SP-1123-1  445020	04 INSTALLED BY CONTINENTAL
950-1123-001M E41169 U5305/5408-1FC NEW	MOTOR, RECYCLED PULP DILUTION CONVEYOR	TOSHIBA	5061 75 HP 1800 365T	CR-20-L-0180-D CR-94-L-0201-D	SP-4200-2  445013	04 INSTALLED BY CONTINENTAL
950-1140-001 M41175 NEW	PUMP, HD STOCK DILUTION	SULZER PROCESS PUMPS APT 43-10 12 X 10 - 15 5200 GPM @ 130 FT.		CR-20-L-0184-D CR-20-M-0311-D  P20272	SP-1140-1  445014	06 ON CENTRAL W.W. CHEST 3102
950-1140-001M E41175 S5304A-1A NEW	MOTOR, HD STOCK DILUTION PUMP	TOSHIBA	5751 250 HP 1800 5010US	CR-20-L-0184-D CR-20-M-0311-D  SL007202	SP-4200-1  445013	06 3102
950-1140-002 M41176 NEW	PUMP, PM WW SUPPLY	SULZER PROCESS PUMPS APT 52-14 16 X 14 - 20 7500 GPM @ 50 FT		CR-20-L-0184-D CR-20-M-0311-D  P20044	SP-1140-1  445014	06 ON CENTRAL WW CHEST 3102

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 137 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1140-002M E41176 U5309-4FD NEW	MOTOR, PM WW SUPPLY PUMP	TOSHIBA	5093 125 HP 900 447TS	CR-20-L-0184-D CR-20-M-0311-D  SL003113	SP-4200-1  445013	06 3102
950-1140-003 M41167  NEW	PUMP, NO.1 HD STORAGE CHEST	SULZER PROCESS PUMPS APT 52-14 16 X 14 - 20 7283 GPM @ 36 FT.		CR-20-L-0180-D CR-20-M-0280-D  P20044	SP-1140-1  445014	04 1000
950-1140-003M E41167 U5309-4RB NEW	MOTOR, NO.1 HD STORAGE CHEST PUMP	TOSHIBA	5086 100 HP 900 445TS	CR-20-L-0180-D CR-20-M-0280-D  SL003110	SP-4200-1  445013	06 1000
950-1140-004 M41168  NEW	PUMP, NO.2 HD STORAGE CHEST	SULZER PROCESS PUMPS APT 52-14 16 X 14 - 20 7283 GPM @ 36 FT.		CR-20-L-0180-D CR-20-M-0280-D  P20044	SP-1140-1  445014	04 1000
950-1140-004M E41168 U5413-2RB NEW	MOTOR, NO.2 HD STORAGE CHEST PUMP	TOSHIBA	5087 100 HP 900 445TS	CR-20-L-0180-D CR-20-M-0280-D  SL003110	SP-4200-1  445013	06 1000
950-1140-005 M41177  NEW	PUMP, CENTRAL WW STANDBY	SULZER PROCESS PUMPS APT 52-14 16 X 14 - 20 5200 GPM @ 130 FT.		CR-20-L-0184-D CR-20-M-0311-D  20278	SP-1140-1  445014	06 ON CENTRAL W.W. CHEST 3102
950-1140-005M E41177 S5406A-1A NEW	MOTOR, CENTRAL WW STANDBY PUMP	TOSHIBA	5750 300 HP 1200 5010US	CR-20-L-0184-D CR-20-M-0311-D  SL007202	SP-4200-1  445013	06 3102
950-1140-006 M41178  NEW	PUMP, DILUTION WW BOOSTER	SULZER PROCESS PUMPS APT 33-4C 6 X 4C - 16 1300 GPM @ 160 FT.		CR-20-L-0180-D CR-20-M-0280-D  P20033	SP-1140-1  445014	06 1000

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 138 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
950-1140-006M E41178 U5305/5408-3FC NEW	MOTOR, DILUTION WW BOOSTER PUMP	TOSHIBA	5088 100 HP 1800 405T	CR-20-L-0180-D CR-20-M-0280-D SL003108	SP-4200-1 445013	06 1000
950-1140-007 M41179 NEW	PUMP, CENTRAL WW CHEST TO RECYCLED FIBER WW CHEST	SULZER PROCESS PUMPS APT 52-14 16 X 14 - 20 7500 GPM @ 82 FT.		CR-20-L-0184-D CR-20-M-0311-D 20278	SP-1140-1 445014	06 3102 ON CENTRAL W.W. CHEST
950-1140-007M E41179 S5003-7A NEW	MOTOR, CENTRAL WW CHEST TO RECYCLED FIBER WW CHEST PUMP	TOSHIBA	5752 200 HP 1200 5010US	CR-20-L-0184-D SL007202	SP-4200-1 445013	06 3102
950-1140-010 M41182 NEW	PUMP, NO.1 DILUTE SULFURIC ACID METERING	NATIONAL PROCESS ANSIMAG KF 31510 C25 3X1.5X10 267 GPM @ 302 FT		CR-20-L-0185-D CR-20-P-0282-D 1P1449	SP-1141-1 445034 955 LBS.	06 2% ACID MAGNETIC DRIVE 3102
950-1140-010M E41182 U5309-4RA NEW	MOTOR, NO.1 DILUTE SULFURIC ACID METERING PUMP	NATIONAL PROCESS TECO ADVANTAGE	5938 50 HP 3600 326TSC	CR-20-L-0185-D CR-20-P-0282-D 1P1449	SP-1141-1 445034	06 3102
950-1140-011 M41183 NEW	PUMP, NO.2 DILUTE SULFURIC ACID METERING	NATIONAL PROCESS ANSIMAG KF 31510 C25 3X1.5X10 267 GPM @ 302 FT.		CR-20-L-0185-D CR-20-P-0282-D 1P1449	SP-1141-1 445034	06 2% ACID MAGNETIC DRIVE 3102
950-1140-011M E41183 U5305/5408-2FD NEW	MOTOR, NO.2 DILUTE SULFURIC ACID METERING PUMP	NATIONAL PROCESS TECO ADVANTAGE	50 HP (est) 3600 326TSC	CR-20-L-0185-D CR-20-P-0282-D 1P1449	SP-1141-1 445034 955 LBS	06 3102
950-1140-012 M4084 NEW	PUMP, WW STORAGE CHEST TO BLEACHED GWD CHEST	ITT / GOULDS 3175 4 X 6 -14 1200 GPM @ 160 FT.		CR-20-L-177 CR-20-P-0277-D HOLJ101006	SP-1140-1 445038	06 3100

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 139 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1140-012M E40165 U5011A-2FD NEW	MOTOR, WW STORAGE CHEST TO BLEACHED GWD CHEST PUMP	TOSHIBA	5090 75 HP 1800 365T	CR-20-L-177 CR-20-P-0277-D  SL003107	SP-4200-2  445013	06 3100
950-1140-016 M57176  NEW	PUMP, PM 3 CLOUDY WW TO BROKE PULPER SHOWERS	ITT / GOULDS 3175 8 X 10 - 18 2400 GPM @ 184 FT.		CR-24-L-74-D CR-20-P-0276-D  A1-244592	SP-1140-1  445038	06 3100
950-1140-016M E57176 S5003-7B NEW	MOTOR, PM 3 CLOUDY WW TO BROKE PULPER SHOWERS PUMP	TOSHIBA	5749 200 HP 1800 5010US	CR-24-L-74-D CR-20-P-0276-D  OL-51042	SP-4200-2  445013	06 3100
950-1140-020 M41197  NEW	PUMP, SODIUM HYDROXIDE PH CONTROL	FRANK HEMMEN SE032MS1E8/138 MONOFLO, 205 RPM 3 GPM @ 172 FT.		CR-20-L-0191-D CR-20-M-0310-D  210135H	SP-1141-2  445052	06 PROGRESSIVE CAVITY SKID MOUNTED 3102
950-1140-020M E41197 U5305/5408-2FA NEW	MOTOR, SODIUM HYDROXIDE PH CONTROL PUMP	FRANK HEMMEN WESTINGHOUSE W/GEAR REDUCER RATIO 8:1	5948 1 HP 1800 143TC	CR-20-L-0191-D CR-20-M-0310-D  210135H	SP-1141-2  445052	06 SKID MOUNTED-3102
950-1140-025 M41194  NEW	PUMP, RECYCLED FIBER LC STORAGE TO PM 1	ITT / GOULDS 3175 6 X 8 - 22 1520 GPM @ 185 FT.		CR-20-L-0183-D CR-20-M-0312 D  A1-244591	SP-1140-1  445038	06 3102
950-1140-025M E41194 U5011A-1FB NEW	MOTOR, RECYCLED FIBER LC STORAGE TO PM 1 PUMP	TOSHIBA	5091 150 HP 1200 447TS	CR-20-L-0183-D CR-20-M-0312 D  	SP-4200-1  445013	06 3102
950-1140-026 M41195  NEW	PUMP, RECYCLED FIBER LC STORAGE TO PM 3	ITT / GOULDS 3175 10 X 8 - 18 2650 GPM @ 200 FT		CR-20-L-0183-D CR-20-M-0312 D  A244639T	SP-1140-1  445038	06 3102


 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>		Page: 140 of 152
		Mill Area: 950		Revision: 08
		BALANCE OF PLANT		Project no: AFCP-001 Document no: 990-01-0901

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1140-026M E41195 S5304A-1B NEW	MOTOR, RECYCLED FIBER LC STORAGE TO PM 3 PUMP	TOSHIBA	5753 250 HP 1800 5010US	CR-20-L-0183-D CR-20-M-0312 D SL007202	SP-4200-1 445013	06 3102
950-1140-904 M45104  EXISTING	PUMP, BLEACHED GWD TO BLEND TANK PM	GOULDS 3175 4 X 10 - 18 1500 GPM @ 143FT	100 HP (est) 1800	CR-20-L-0182-D ---	---	05
950-1140-909 M54509  EXISTING	PUMP, CLEAR WELL NO. 1 (PM 4)		200 HP (est) 1200	CR-220-L-19-D ---	---	05
950-1140-910 M54510  EXISTING	PUMP, PM 4 CLOUDY W.W.		200 HP (est) 1200	CR-220-L-19-D ---	---	05
950-1140-918 Z  EXISTING	PUMP, DECKER STOCK CHEST NO.3 TO BLEACHED GWD	GOULDS 3175 4 X 6 - 18 1400 GPM @ 242 FT	125 HP (est) 1800	CR-20-L-0175-D ---	---	04 MOTOR EQ. E45104
950-1140-919 M45119  EXISTING	PUMP, DECKER STOCK CHEST NO.4 TO BLEACHED GWD	GOULDS 3175 4 X 6 - 18 1300 GPM @ 254 FT	125 HP (est) 1800	CR-20-L-0175-D ---	---	04
950-1140-935 M52135  EXISTING	PUMP, JOHNSON SCREEN WATER TO GWD	GOULDS 3175 10 X 8 - 18H 3100 GPM @ 152 FT.		CR-22-L-149 ---	---	04
950-1140-935M E201  EXISTING	MOTOR, JOHNSON SCREEN WATER TO GWD PUMP		100 HP (est) 1200	CR-22-L-149 ---	---	06


 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 141 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02




EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1140-957 M3357  MODIFIED	PUMP, RECYCLED FIBER LC STORAGE TO PM 4	GOULDS 3175 10 X 8 -18 3154 GPM @ 189 FT.		CR-20-L-0183-D CR-20-M-0312 D	SP-1140-1  445038	06 SPEED UP TO 1800 RPM NEW IMPELLER REQ'D NEW MOTOR REQ'D-3101
950-1140-957M E41196 S5406A-1B NEW	MOTOR, RECYCLED FIBER LC STORAGE TO PM 4 PUMP	TOSHIBA	5754 250 HP 1800 5010US	CR-20-L-0183-D CR-20-M-0312 D  SL007202	SP-4200-1  445013	06 3101
950-1140-997 M4297  REMOVED	PUMP, RECYCLED FIBER LC STORAGE TO PM 3	ALLIS-CHALMERS P.W.G. 8 X 6 2000 GPM @ 110 FT.			---  ---	05 NEW PUMP AND MOTOR REQUIRED, SEE M41195 AND E41195
950-1143-001 M41181  NEW	PUMP, 98% SULFURIC ACID METERING	NATIONAL PROCESS MILROYAL B MBH 3.5 GPM @ 55 FT		CR-20-L-0185-D CR-20-P-0282-D  PD3641	SP-1141-1  445034	06 3102
950-1143-001M E41181 U5305/5408-2FC NEW	MOTOR, 98% SULFURIC ACID METERING PUMP	NATIONAL PROCESS TECO ADVANTAGE	5937 1 HP 1800 143TC	CR-20-L-0185-D CR-20-P-0282-D	SP-1141-1  445034 400 LBS	06 3102
950-1143-003 M41187  NEW	PUMP, NO.1 SODIUM HYDROSULFITE	NATIONAL PROCESS KONTRO GTA 1 X 1 X 6 C-A44 19.3 GPM @ 139 FT		CR-20-M-0310-D  104762 D01	SP-1141-1  445034	06 3102 MAGNETIC DRIVE SKID MOUNTED
950-1143-003M E41187 U5311-3FA NEW	MOTOR, NO.1 SODIUM HYDROSULFITE PUMP	NATIONAL PROCESS TECO ADVANTAGE	5941 7.5 HP 3600 213TC	CR-20-M-0310-D  104762D01	SP-1141-1  445034	06 3102
950-1143-004 M41188  NEW	PUMP, NO.2 SODIUM HYDROSULFITE	NATIONAL PROCESS KONTRO GTA 1 X 1 X 6 C-A4 19.3 GPM @ 139 FT		CR-20-M-0310-D  104762 D01	SP-1141-1  445034	06 3102 MAGNETIC DRIVE SKID MOUNTED

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 142 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
950-1143-004M E41188 U5018-2FD NEW	MOTOR, NO.2 SODIUM HYDROSULFITE PUMP	NATIONAL PROCESS	5942 7.5 HP 3600 213TC	CR-20-M-0310-D 104762D01	SP-1141-1 445034	06 3102
950-1143-005 M41192 NEW	PUMP, NO.1 TALC FEED	FRANK HEMMEN SE0034MS1A8/E MONOFLO, 222 RPM 3.4 GPM @ 268,2 FT.		CR-20-L-0186-D CR-20-M-0310-D 210135G	SP-1141-2 445052	06 3102 PROGRESSIVE CAVITY SKID MOUNTED
950-1143-005M E41192 U5309-4FA NEW	MOTOR, NO.1 TALC FEED PUMP	FRANK HEMMEN WESTINGHOUSE W/GEAR REDUCER RATIO 8:1	5946 2 HP 1800 145TC	CR-20-L-0186-D CR-20-M-0310-D 210135G	SP-1141-2 445052	06 3102 SKID MOUNTED
950-1143-006 M41193 NEW	PUMP, NO.2 TALC FEED	FRANK HEMMEN SE0034MS1A8/E MONOFLO, 222 RPM 3.4 GPM @ 268,2 FT.		CR-20-L-0186-D CR-20-M-0310-D 210135G	SP-1141-2 445052	06 3102 PROGRESSIVE CAVITY SKID MOUNTED
950-1143-006M E41193 U5018-3RD NEW	MOTOR, NO.2 TALC FEED PUMP	FRANK HEMMEN WESTINGHOUSE W/GEAR REDUCER RATIO 8:1	5947 2 HP 1800 145TC	CR-20-L-0186-D CR-20-M-0310-D 210135G	SP-1141-2 445052	06 3102 SKID MOUNTED
950-1150-001 M41201 NEW	PUMP, EFFLUENT CHAMBER SUMP	JOHN BROOKS ZOELLER E57 CAST IRON		CR-94-L-0090-D CR-53-M-0013 JS061901A	SP-1150-1 445024	06
950-1150-001M E41201 NEW	MOTOR, EFFLUENT CHAMBER SUMP PUMP	JOHN BROOKS E57	0.33 HP (est) 1550	CR-94-L-0090-D CR-53-M-0013 JS061901A	SP-1150-1 445024	06
950-1180-001 M41165 NEW	AGITATOR, NO.1 RECYCLED PULP HD STORAGE CHEST	MIXPRO 70VSH-150-290 IMP. DIA. 45.0" 290 RPM . SF=1.50		CR-20-L-0180-D CR-20-M-0280-D U00U013-07	SP-1180-1 445009 8000 LBS	04 1000 316 SS

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 143 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
950-1180-001M E41165 U5311-1FA NEW	MOTOR, NO.1 RECYCLED PULP HD STORAGE CHEST AGITATOR	TOSHIBA B1506FLF4BSHD TEFC	5033 150 HP 1200 447T	CR-20-L-0180-D CR-20-M-0280-D SL003114	SP-4200-2 445013 2314 LBS	04 C/W SLIDE BASE 1000
950-1180-002 M41166 NEW	AGITATOR, NO.2 RECYCLED PULP HD STORAGE CHEST	MIXPRO 70VSH-150-290 IMP. DIA. 45.0" 290 RPM . SF=1.50		CR-20-L-0180-D CR-20-M-0280-D U00U013-07	SP-1180-1 445009 8000 LBS	04 1000 316 SS
950-1180-002M E41166 U5413-1RB NEW	MOTOR, NO.2 RECYCLED PULP HD STORAGE CHEST AGITATOR	TOSHIBA B1506FLF4BSHD TEFC	5034 150 HP 1200 447T	CR-20-L-0180-D CR-20-M-0280-D SL003114	SP-4200-2 445013 2314 LBS	04 C/W SLIDE BASE 1000
950-1180-003 M41173 NEW	AGITATOR, NO.1 CENTRAL WW CHEST	MIXPRO 40VST-60-316 IMP. DIA. 36.0" 316 RPM . SF=1.58		CR-20-L-0184-D CR-20-M-0311-D U00U013-08	SP-1180-1 445009 3400 LBS	06 3102 316 SS
950-1180-003M E41173 U5311-3FB NEW	MOTOR, NO.1 CENTRAL WW CHEST AGITATOR	TOSHIBA B0606FLF3BSHD TEFC	5035 60 HP 1200 365T	CR-20-L-0184-D CR-20-M-0311-D SL003108	SP-4200-2 445013 1381 LBS	06 C/W SLIDE BASE 3102
950-1180-004 M41191 NEW	AGITATOR, TALC STORAGE TANK	LIGHTNIN / NORTEC 5042 7.5T 3" SHAFT, 2 X 48" DIA. IMP. 68 RPM		CR-20-L-0186-D CR-20-M-0310-D R241034-A	SP-1180-2 445043	06 C/W MOTOR S/N R0124103401 3102
950-1180-004M E41191 U5305/5408-3FA NEW	MOTOR, TALC STORAGE TANK AGITATOR	LIGHTNIN / NORTEC	5966 7.5 HP 1800 213TC	CR-20-L-0186-D CR-20-M-0310-D R241034-A	SP-1180-2 445043	06 3102
950-1180-005 M41174 NEW	AGITATOR, NO.2 CENTRAL WW CHEST	MIXPRO 40 VST-60-316 IMP.DIA 36.0" 316 RPM SF = 1.58		CR-20-L-0184-D CR-20-M-0311-D U00U013-08	SP-1180-1 445009 1381 LBS	06 3102

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950 BALANCE OF PLANT	Page: 144 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1180-005M E41174 U5018-4FC NEW	MOTOR, NO.2 CENTRAL WW CHEST AGITATOR	TOSHIBA	5094 60 HP 1200 365T	CR-20-L-0184-D CR-20-M-0311-D  SL003108	SP-4200-2  445013	06 3102
950-1180-006 M41204  NEW	AGITATOR, NO.1 RECYCLED FIBER LC STORAGE CHEST	MIXPRO 60VSH-150-244 IMP. DIA. 60" 244 RPM		CR-20-L-0183-D CR-20-M-0312 D  U00U013	SP-1180-1  445009	06 3102
950-1180-006M E41204 S5406A-2A NEW	MOTOR, NO.1 RECYCLED FIBER LC STORAGE CHEST AGITATOR	TOSHIBA	5755 200 HP 1200 5010UZ	CR-20-L-0183-D CR-20-M-0312 D  SL007202	4200-1  445013	06 V-BELT DRIVE CUSTOM SLIDE BASE 3102
950-1180-007 M41205  NEW	AGITATOR, NO.2 RECYCLED FIBER LC STORAGE CHEST	MIXPRO 60VSH-150-244 IMP. DIA. 60" 244 RPM		CR-20-L-0183-D CR-20-M-0312 D  U00U013-09	SP-1180-1  445009	06 3102
950-1180-007M E41205 S5304A-2A NEW	MOTOR, NO.2 RECYCLED FIBER LC STORAGE CHEST AGITATOR	TOSHIBA	5756 200 HP 1200 5010UZ	CR-20-L-0183-D CR-20-M-0312 D  SL007202	4200-1  445013	06 V-BELT DRIVE CUSTOM SLIDE BASE 3102
950-1180-008 M41206  NEW	AGITATOR, NO.3 RECYCLED FIBER LC STORAGE CHEST	MIXPRO 60VSH-150-244 IMP. DIA. 60" 244 RPM		CR-20-L-0183-D CR-20-M-0312 D  U00U013-09	SP-1180-1  445009	06 3102
950-1180-008M E41206 S5304A-2B NEW	MOTOR, NO.3 RECYCLED FIBER LC STORAGE CHEST AGITATOR	TOSHIBA	5757 200 HP 1200 5010UZ	CR-20-L-0183-D CR-20-M-0312 D  SL007202	4200-1  445013	06 V-BELT DRIVE CUSTOM SLIDE BASE 3102
950-1180-009 M41207  NEW	AGITATOR, NO.4 RECYCLED FIBER LC STORAGE CHEST	MIXPRO 60VSH-150-244 IMP. DIA. 60" 244 RPM		CR-20-L-0183-D CR-20-M-0312 D  U00U013-09	SP-1180-1  445009	06 3102

 <b>AJAMI, BEDARD, GAGNON, SEXTON INC.</b> PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 145 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1180-009M E41207 S5406A-2B NEW	MOTOR, NO.4 RECYCLED FIBER LC STORAGE CHEST AGITATOR	TOSHIBA	5758 200 HP 1200 5010UZ	CR-20-L-0183-D CR-20-M-0312 D  SL007202	4200-1  445013	06 V-BELT CUSTOM SLIDE BASE 3102
950-1181-001 M41184  NEW	MIXER, SULFURIC ACID STATIC	HIMIC-STATIFLO SERIES 300 40" DIA. TEFLON LINED 4 ELEMENTS		CR-20-L-0185-D CR-20-P-0282-D  300-001 IN	SP-1181-1  445068	06 3102 C/W INJECTION QUILL
950-1242-001 M41164  NEW	CHEST, RECYCLED PULP HD STORAGE	CHEMIPULP PROCESS  54'-0" DIA. x 79'-11" H. 600 TONS		CR-20-L-0180-D CR-20-M-0280-D  22-4129-01	SP-1242-1  445019	04 ERECTED BY CHEMIPULP
950-1242-002 M41203  NEW	CHEST, RECYCLED FIBER LC STORAGE	CHEMIPULP PROCESS  53'-6" DIA. X 60'-0" H 3.5% CONS. / 2 HR. RET.		CR-20-L-0183-D CR-20-M-0312 D  22-4152-03	SP-1242-2  445019	06
950-1242-901 M4364  DEMOLISH	CHEST, GWD STORAGE			CR-20-L-0181-D   ---	---	06
950-1242-902 M4130  MODIFIED	CHEST, CENTRAL WW (WAS DE-INK STORAGE TANK)			CR-20-L-0184-D CR-20-M-0311-D  22-4155-01	---	07 TO BE MODIFIED BY CHEMIPULP
950-1242-903 M5072  EXISTING	TANK, 2% DILUTE ACID			CR-20-L-0185-D CR-20-P-0282-D  ---	---	06 3102
950-1246-001 M41202  NEW	TANK, SODIUM HYDROXIDE STORAGE	APACHE STAIN. EQUIP. CARBON STEEL 10'-0" X15'-6" S.W. 8000 USGAL.		CR-20-L-0191-D CR-20-M-0310-D  D3777-01	SP-1246-1  445057	06 PRIMER EXTERIOR AMERCOAT INTERIOR 3102


 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 146 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1247-001 M41185  NEW	TANK, SODIUM HYDROSULFITE STORAGE	APACHE STAIN. EQUIP. 316 LSS 14'-0" D X 36'-0" S.W 40000 GAL.		CR-20-M-0310-D   D3769-06	SP-1246-1  445057	06 3102
950-1247-003 M41190  NEW	TANK, TALC STORAGE	APACHE STAIN. EQUIP. SA 240, 304L 10'-0" D X 16'-0" S.W. 8000 GAL		CR-20-L-0186-D CR-20-M-0310-D  D-38-769-04	SP-1246-1  445057 6500 LBS	06 3102
950-1281-001 M41171  NEW	HEATER, HD DILUTION STEAM INJECTION	PICK HEATERS 6 X 350-1 FAB 16" X 16" X 6" 35000 LB/HR, 150 PSI		CR-20-L-0180-D CR-20-P-0273-D  SK001208F-C	SP-1281-1  445025 1050 LBS	06 SN 1200-10 ALL 316SS 3102
950-1281-002 M4088  NEW	HEATER, BLEACHED GWD DILUTION WW STEAM INJECTION	PICK HEATERS 6 X 150 - 1 FAB 8" X 8" X 3" 15000 LB/HR		CR-20-L-177 CR-20-P-0277-D  ABGS 0101-17-3	SP-1281-1  445025 500 LBS	06 3100
950-1290-001 M41199  NEW	WATER TEMPERING UNIT, BOP CHEMICAL AREA	ARMSTRONG 535P-PTW40R  60GPM @ 90°F		CR-20-L-0190-D CR-20-P-0274-D  YD1297-C	SP-3550-1  445076	06 3102
950-1290-002 M41200  NEW	PUMP, BOP CHEMICAL AREA WATER TEMPERING UNIT	ARMSTRONG ASTRO		CR-20-L-0190-D CR-20-P-0274-D  yd1297-c	SP-3550-1  445076	06 3102
950-1290-002M E41200  NEW	MOTOR, BOP CHEMICAL AREA WATER TEMPERING UNIT PUMP	ARMSTRONG	5 HP (est) 1800	CR-20-L-0190-D CR-20-P-0274-D  YD1297-C	SP-3550-1  445076	06 3102 SUPPLIED W/EQUIPMENT 110V
950-1420-001 T41169  NEW	REDUCER, DILUTION SCREW CONVEYOR	CONTINENTAL CONVEYOR HANSEN SFN75B14I-B3 RATIO 14.08:1		CR-20-L-0180-D CR-20-M-0280-D  TD-122-217D	SP-1123-1  445020	06 INSTALLED BY CONTINENTAL


 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 147 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02




EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-1535-001 M41198  NEW	SYSTEM, NITROGEN SUPPLY	HOLOX			---	05 3102  BY MILL
950-3520-001  NEW	EXPANSION JOINT, NO.1 WW LINE TO RECYCLED FIBER PLANT	THORNBURN  16" DIA.		CR-20-L-0180-D	SP-3520-2  445069	06 INSTALLED BY CONTINENTAL ON LINE 16"-020-WWC-010
950-3520-002  NEW	EXPANSION JOINT, NO.2 WW LINE TO RECYCLED FIBER PLANT	THORNBURN  16" DIA.		CR-20-L-0180-D	SP-3520-2  445069	06 INSTALLED BY CONTINENTAL ON LINE 16"-020-WWC-010
950-3520-003  NEW	EXPANSION JOINT, NO.3 WW LINE TO RECYCLED FIBER PLANT	THORNBURN  16" DIA.		CR-20-L-0180-D	SP-3520-2  445069	06 INSTALLED BY CONTINENTAL ON LINE 16"-020-WWC-010
950-3520-005  SPARE	EXPANSION JOINT, WW LINE TO RECYCLED FIBER PLANT	THORNBURN  16" DIA.			SP-3520-2  445069	06 SPARE
950-3550-001  NEW	SAFETY SHOWER, HYDROSULFITE AND TALC UNLOADING AREA	ENCON 330A0000100		KW (est) CR-20-M-0310-D  330A0000100	SP-3550-1  445074	06 3102 HEAT TRACED
950-3550-002  NEW	SAFETY SHOWER, HYDROSULFITE AND TALC CONTAINMENT AREA	ENCON 330A0000100		KW (est) CR-20-M-0310-D  330A0000100	SP-3550-1  445074	06 3102 HEAT TRACED
950-3550-003  NEW	SAFETY SHOWER, HD STORAGE AREA	ENCON 330A0000100		KW (est) CR-20-M-0280-D  330A0000100	CR-20-L-0180-D SP-3550-1 445074	06 3102 HEAT TRACED

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 148 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-4165-001 20-UPS-01  NEW	UNIT, UNINTERRUPTABLE POWER SUPPLY (HD TOWER)	MAJOR POWER AXXIUM PRO 0650  7.5 KVA		CR-20-E-0243-D	BM-310-4150-001 445077	05
950-4250-001 D41197  NEW	DRIVE, SODIUM HYDROXIDE PH CONTROL BOOSTER PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-20-L-0180-D	SP-4250-1 445023	06
950-4250-002 D41181  NEW	DRIVE, 98% SULFURIC ACID PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-20-L-0185-D	SP-4250-1 445023	06
950-4250-003 D41192  NEW	DRIVE, NO.1 TALC FEED PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-20-L-0186-D	SP-4250-1 445023	06 3103
950-4250-004 D41193  NEW	DRIVE, NO.2 TALC FEED PUMP VF	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-20-L-0186-D	SP-4250-1 445023	06 3103
950-4305-901 S5003  EXISTING	MOTOR CONTROL CENTER 2.3 KV PAPER MACHINE & DEINK REFINERS	MATTHEWS ELECTRIC ALLEN BRADLEY		CR-20-E-0244-D  7003443-001-01D	--- 445023	06 NEW STARTERS ADDED 4101
950-4305-902 S5304  EXISTING	MOTOR CONTROL CENTER, 2.3KV PM3 3RD	INDUSTRIAL ELECTRIC CUTLER HAMMER		CR-20-E-0245-D	--- BM-950-4300-006 445063	06 NEW STARTERS ADDED 4101
950-4305-903 S5406  EXISTING	MOTOR CONTROL CENTER, 2.3 KV PM4	INDUSTRIAL ELECTRIC CUTLER HAMMER		CR-124-E-0087-D	--- BM-950-4300-005 445063	06 NEW STARTERS ADDED 4101

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 149 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02


EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-4305-904 S5406A  EXISTING	MOTOR CONTROL CENTER, 2.3 KV PM4	INDUSTRIAL ELECTRIC CUTLER HAMMER			BM-950-4300-012 445063	07 2 STARTERS AND LOAD BREAK SWITCH ADDED
950-4305-905 S5304A  EXISTING	MOTOR CONTROL CENTER, 2.3 KV PM 3 3RD	INDUSTRIAL ELECTRIC CUTLER HAMMER			BM-950-4300-013 445063	07 2 STARTERS AND LOAD BREAK SWITCH ADDED
950-4310-001 U5305/5408  NEW	MOTOR CONTROL CENTER 480V	REXEL SOUTHERN ELECT SIEMENS		CR-20-E-0243-D  DJ5W75L001	---  445072	06 4101
950-4310-901 U5011A  EXISTING	MOTOR CONTROL CENTER 480V STOCK PREPARATION	INDUSTRIAL ELECTRIC CUTLER HAMMER		CR-20-E-0243-D	--- 445063	06 NEW STARTERS ADDED 4101
950-4310-902 U5018  EXISTING	MOTOR CONTROL CENTER 480V PM4 2ND	INDUSTRIAL ELECTRIC CUTLER HAMMER		CR-220-E-0046	--- 445063	06 NEW STARTERS ADDED 4101
950-4310-903 U5309  EXISTING	MOTOR CONTROL CENTER 480V, PM3	REXEL SOUTHERN ELECT SIEMENS		CR-20-E-0245-D  DJ5W75U002	--- 445072	06 NEW STARTERS ADDED 4101
950-4310-904 U5413  EXISTING	MOTOR CONTROL CENTER 480, PM4	INDUSTRIAL ELECTRIC CUTLER HAMMER		CR-124-E-0087-D	--- 445063	06 NEW STARTERS ADDED 4101
950-4310-905 U5311  EXISTING	MOTOR CONTROL CENTER 480V, PM3	REXEL SOUTHERN ELECT SIEMENS		CR-20-E-0248-D	--- 445072	06 NEW STARTER ADDED 4101

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950 BALANCE OF PLANT	Page: 150 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION REMARKS
950-4310-906 U5019  EXISTING	MOTOR CONTROL CENTER 480V, PM4	INDUSTRIAL ELECTRIC CUTLER HAMMER		CR-220-E-0046	--- 445063	07 NEW STARTER ADDED
950-4315-001 ATS-U5305/54  NEW	SWITCH, AUTOMATIC TRANSFER	MAYER ELECTRIC ASCO POWER  800A		CR-20-E-0243-D  617408	SP-4310-1 445048	06 4101
950-4360-100 94-PLC/C-03  NEW	PLC, COMMON B.O.P. REMOTE I/O CABINET	LAURENTIDE CONTROLS		CR-94-I-0045-D	445016	06 WAS NUMBERED 300-4360-100
950-4440-001 M41198  NEW	HEATER, TALC STORAGE TANK ELECTRIC	HEAT TRACE 10-EGLX PANELS 5.0 KW 240V/21A	5 KW (est)	CR-20-L-0186-D CR-220-E-0044  D-296	SP-4440-1 445067	06 IPP-U5305/5408-A CCT # 37;39
950-4440-002 M41196  NEW	HEATER, SODIUM HYDROXIDE STORAGE TANK ELECTRIC	HEAT TRACE 8-EGLX PANELS 4KW 240 V 28A		CR-20-L-0191-D CR-220-E-0044  D-314	SP-4440-1 445067	06
950-6381-001M E41208 U5011A-1FA NEW	MOTOR, CONSISTENCY TRANSMITTER TAG NO. 57-KE-0002	BTG ROTARY TYPE MEK-2300 480 V, 3 PH.	0.3 KW (est)	CR-20-L-0183-D CR-20-I-0012-D	SP-6381-1 445033	06 SUPPLIED WITH INSTRUMENT
950-6381-002M E41209 U5309-4FB NEW	MOTOR, CONSISTENCY TRANSMITTER TAG NO. 57-KE-0003	BTG ROTARY TYPE MEK-2300 480 V, 3 PH.	0.3 KW (est)	CR-20-L-0183-D CR-20-I-0012-D	SP-6381-1 445033	06 SUPPLIED WITH INSTRUMENT
950-6381-003M E41210 U5019-2FA NEW	MOTOR, CONSISTENCY TRANSMITTER TAG NO. 57-KE-0102	BTG ROTARY TYPE MEK-2300 480 V, 3 PH.	0.3 KW (est)	CR-20-L-0183-D CR-20-I-0012-D	SP-6381-1 445033	06 SUPPLIED WITH INSTRUMENT

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<b>EQUIPMENT LIST</b>  Mill Area: 950  BALANCE OF PLANT	Page: 151 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02

EQUIPMENT NO CLIENT NO CIRCUIT NO STATUS	DESCRIPTION	MANUFACTURER MODEL SIZE RATING	MOTOR NO RATED POWER RPM FRAME	P/I DIAGRAM EQ.LAY.DWG FOUND.DWG MFR. DWG	SPEC. NO B/M NO P.O. NO WEIGHT	REVISION    REMARKS
950-6381-004M E41211 U5305/5408-4FC NEW	MOTOR, CONSISTENCY TRANSMITTER TAG NO. 57-KE-0616	BTG ROTARY TYPE MEK-2300 480 V, 3 PH.	0.3 KW (est)	CR-20-L-0180-D CR-20-I-0012-D	SP-6831-1 445033	06 SUPPLIED WITH INSTRUMENT
950-6410-001  NEW	CABINET, NO.4 HD TOWER DCS	LAURENTIDE CONTROLS DELTA-V CABINET 49" X 36" X 12" WALL MOUNT NEMA 4X		CR-94-I-0045-D	445016	07

 <b>ABGS</b> AJAMI, BEDARD, GAGNON, SEXTON INC. PULP AND PAPER CONSULTANTS Montreal, Quebec	<b>ALLIANCE FOREST PRODUCTS</b>  COOSA PINES, ALABAMA RECYCLED FIBER PLANT	<u><b>EQUIPMENT LIST</b></u>  Mill Area: 950  BALANCE OF PLANT	Page: 152 of 152
			Project no: AFCP-001 Document no: 990-01-0901
			Revision: 08 Date: 5/21/02